

CO₂ Concentration results (in ppm)

ELEMENTARY SCHOOLS							
School	Ventilation Type	Nb of classes tested	Nb of readings	Less than 1000	Between 1000 and 1500	Between 1500 and 2000	Over 2000
A.D.S. Elementary School	Natural	5	15	9	6	0	0
Ayer's Cliff Elementary School	Natural	4	12	9	3	0	0
Butler Elementary School	Natural	6	18	11	7	0	0
Cookshire Elementary School	Natural	7	21	20	1	0	0
Drummondville Elementary School	Natural	7	21	10	11	0	0
Farnham Elementary School	Natural	4	12	8	4	0	0
Heroes Elementary School	Natural	6	18	18	0	0	0
Knowlton Elementary School	Natural	6	18	17	1	0	0
Lennoxville Elementary School	Natural	8	24	19	5	0	0
Mansonville Elementary School	Natural	4	12	12	0	0	0
North Hatley Elementary School	Natural	4	12	12	0	0	0
Parkview Elementary School	Natural	4	12	12	0	0	0
Pope Elementary School	Natural	5	15	14	1	0	0
Princess Elizabeth Elementary School	Natural	4	12	8	4	0	0
Sawyerville Elementary School	Natural	5	15	15	0	0	0
Sherbrooke Elementary School	Natural	8	24	21	3	0	0
Saint-Francis Elementary School	Natural	8	24	22	2	0	0
Sunnyside Elementary School	Natural	7	21	21	0	0	0
Sutton Elementary School	Natural	4	12	12	0	0	0
Waterloo Elementary School	Natural	8	24	24	0	0	0
HIGH SCHOOLS							
School	Ventilation type	Nb of classes tested	Nb of readings	Less than 1000	Between 1000 and 1500	Between 1500 and 2000	Over 2000
Alexander Galt Regional High School	Natural	6	18	11	7	0	0
Massey-Vanier High School*	Mechanical	8	24	24	0	0	0
Richmond Regional High School	Naturel	4	12	11	1	0	0
CENTRES							
Centre	Ventilation type	Nb of classes tested	Nb of readings	Less than 1000	Between 1000 and 1500	Between 1500 and 2000	Over 2000
CBM Adult Education Centre*	Mechanical	7	21	21	0	0	0
Lennoxville Vocational Training Centre	Natural	4	12	12	0	0	0
New Horizons Adult Education Centre	Natural	4	12	10	2	0	0
TOTALS	-	147	441	383	58	0	0
TOTALS (by percentage)	-	-	-	86.8%	13.2%	-	-

*Data collected by the "Centre de services scolaire du Val-des-Cerfs".