

DRINKING WATER LEAD TEST RESULTS

ELEMENTARY SCHOOLS							
	Number of water points tested			Corrective Measures			Updated conformed water points
School	Total	Conform	Non Conform	Faucet(s)/ Water fountain(s) replacement or addition	Connector(s)/valv(s) replacement	Pipes replacement	Total conform/ Total tested
A.D.S. Elementary School	6	5	1	●	●		6/6
Ayer's Cliff Elementary School	7	7	0				7/7
Butler Elementary School	7	6	1	●	●		7/7
Cookshire Elementary School	9	5	4	●	●	●	9/9
Drummondville Elementary School	10	10	0				10/10
Farnham Elementary School	5	1	4	●	●	●	5/5
Heroe's Elementary School	10	10	0				10/10
Knowlton Elementary School	12	8	4	●			14/14*
Lennoxville Elementary School	9	6	3	●		●	10/10*
Mansonville Elementary School	5	4	1	●			5/5
North Hatley Elementary School	7	6	1			●	7/7
Parkview Elementary School	16	14	2			●	16/16
Pope Elementary School	6	6	0				6/6
Princess Elizabeth Elementary School	9	5	4	●		●	10/10*
Sawyerville Elementary School	9	7	2	●		●	10/10*
Sherbrooke Elementary School	11	11	0				11/11
Saint-Francis Elementary School	12	12	0	●			12/12
Sunnyside Elementary School	16	14	2			●	16/16
Sutton Elementary School	9	9	0				9/9
Waterloo Elementary School	9	8	1	●			9/9

* Difference between the total water points tested and the updated conformed water points is due to addition and/or retrieval of water points.

HIGH SCHOOLS							
School	Water points tested			Corrective Measures			Updated Conform water points
	Total	Conform	Non Conform	Faucet(s)/ Water fountain(s) replacement	Connector(s)/valv(s) replacement	Pipes replacement	Total conform/ Total tested
Alexandar Galt Regional High School	46	27	19	●	●	●	45/45
Richmond Regional High School	22	15	7	●	●	●	29/29*

* Difference between the total water points tested and the updated conformed water points is due to addition and/or retrieval of water points.

CENTRES							
School	Water points tested			Correctives			Updated Conform water points
	Total	Conform	Non Conform	Faucet(s)/ Water fountain(s) replacement	Connector(s)/valv(s) replacement	Pipes replacement	Total conform/ Total tested
Lennoxville Vocational Training Center	11	6	5	●	●	●	13/13*
New Horizon	10	4	6	●	●	●	10/10

* Difference between the total water points tested and the updated conformed water points is due to addition and/or retrieval of water points.